

# PAT4 COMPACT APPLIANCE TESTING CERTIFICATE

## CLIENT AND LOCATION DETAILS

**Certificate No.:** 106

This form allows data to be imported from: **Megger PAT4**



Serial No.: 3179

**Client Name and Address**

ROLL UP ROLL UP  
1 Heathlands Road  
Little Sutton  
Ellesmere Port  
CH66 5PB

**Location Name and Address**

as Opposite

### TEST RESULTS

Asset ID	Description	Test Date	Visual	Cont 1	Cont 2	Cont 3	Ins.	Oper.	Leak.	Extn.	Flash	Status
0001	110 LEAD	10/06/2010	Pass	-	-	-	>50	0	0	Skip	-	P
0002	240 LEAD	10/06/2010	Pass	-	-	-	>50	0	0.1	Skip	-	P
0003	TEST LEAD	10/06/2010	Pass	-	-	-	>50	0	0	Skip	-	P
0004	TEST LEAD	10/06/2010	Pass	-	-	-	>50	0	0	Skip	-	P
0005	BLOWER	10/06/2010	Pass	0.062	-	-	>50	1.33	0	Skip	-	P
0006	BLOWER	10/06/2010	Pass	0.098	-	-	>50	1.66	0.13	Skip	-	P
0007	240 LEAD	10/06/2010	Pass	-	-	-	>50	0	0.11	Skip	-	P
0008	240 LEAD	10/06/2010	Pass	-	-	-	>50	0	0.11	Skip	-	P
0009	240 LEAD	10/06/2010	Pass	-	-	-	>50	0	0.11	Skip	-	P

### CONTRACTOR DETAILS

**Company Name and Address**

west cheshire electrical testing ltd  
146 Belvidere Road  
Wallasey  
Wirral

Tester Name Jeff Craddock

Qualifications \_\_\_\_\_

Position Electrical Engineer

Signature \_\_\_\_\_